



# City of Calhoun, Utilities

## Cross-Connection Control Program

### Backflow Prevention Assembly Test Form

Location of Assembly: \_\_\_\_\_ Premises Number: \_\_\_\_\_

Type: \_\_\_\_\_ Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Size: \_\_\_\_\_ Serial No.: \_\_\_\_\_

Name of Owner: \_\_\_\_\_

Service Address: \_\_\_\_\_

City, State & Zip Code: \_\_\_\_\_

Tester: \_\_\_\_\_ Certification No.: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Type of Service: \_\_\_\_\_ New Test  Recertification Test  Line Pressure: \_\_\_\_\_

Test Kit: \_\_\_\_\_ Serial No. \_\_\_\_\_ Calibration Date \_\_\_\_\_

NO. 1 CHECK VALVE	NO. 2 CHECK VAVLE	RELIEF VALVE	PRESSURE VACUUM BREAKER
<input type="checkbox"/> Leaked <input type="checkbox"/> Closed Tight Diff Pressure Across Check Valve __. __ PSID	<input type="checkbox"/> Leaked <input type="checkbox"/> Closed Tight Diff Pressure Across Check Valve __. __ PSID	Opened at ____ . ____ PSID	Air Inlet ____ . ____ PSID <input type="checkbox"/> Did not open Check Valve ____ . ____ PSID <input type="checkbox"/> Leaked
<input type="checkbox"/> Cleaned <input type="checkbox"/> Replaced: _____ _____	<input type="checkbox"/> Cleaned <input type="checkbox"/> Replaced: _____ _____	<input type="checkbox"/> Cleaned <input type="checkbox"/> Replaced: _____ _____	<input type="checkbox"/> Cleaned <input type="checkbox"/> Replaced: _____ _____
Closed Tight at ____ . ____ PSID	Closed Tight at ____ . ____ PSID	Opened at ____ . ____ PSID	Air Inlet ____ . ____ PSID Check Valve ____ . ____ PSID
Shut Off Valve #1 _____ Leaked _____ Closed Tight		Buffer: _____	Shut Off Valve #2 _____ Leaked _____ Closed Tight

Comments: \_\_\_\_\_

This Assembly: \_\_\_\_\_ PASSED \_\_\_\_\_ FAILED

I hereby certify that this data is accurate and reflects the proper operation and maintenance of the assembly.

\_\_\_\_\_  
(Signature of Licensed Tester and Date)

\*All Repairs must be made within 10 Business Days

City of Calhoun, Utilities, 700 West Line Street, Calhoun, Georgia 30701, Phone: (706) 629-4701 Fax (706) 602-6079