Fire Marshal's Office
Fireworks Stand Checklist/ Permit

Name _____

Address _____

Owner _____

Phone # _____

Email _____

Date Issued: Permit# Approved: Denied:

	✓	X
A State Fire Marshal's License posted.		
Proof of insurance coverage		
Written Authorization from the property owner which allows use of the site		
Posted Signage: List of legal fireworks, No Smoking, and Photo ID Required.		
Electrical service shall be installed in accordance to NEC & AHJ		
EXIT signs present at each exit.		
Area around stand kept free of dry grass, dry brush, and combustible debris.		
No parking within 20 feet, except when delivering and unloading fireworks.		
Must be minimum of 100' from storage & dispensing of flammables.		
No fireworks may be discharged within 100 feet of a stand.		
NO SMOKING signs with at least 4" letters, posted.		
Generator at least 15' from stand.		
No high grass, weeds, trash near generator.		
ABC extinguisher on site for generator		
Clear aisle ways of at least 24 inches.		
Customers permitted inside only when greater than four hundred square feet.		
Temporary stands shall have two exits at least 28" in width.		
Minimum of 1 approved pressurized 2 ½ gallon water-type fire extinguisher.		
No open flames or flame equipment inside.		
Stand shall be secured when unoccupied if fireworks are kept in the stand.		
Excess cardboard shall be stored in manner preventing ignition.		
Notes:		

NOTE: ALL BUSINESS SHALL COMPLY WITH CITY ORDINANCES, STATE, AND FEDERAL CODES.

You may email your completed permit to: tduvall@calnet-ga.net; lmagonara@calnet-ga.net

Fire Department Office Use Only

Date: Approved By: